

1 TYPICAL RELAY PANEL WIRING DIAGRAM
NO SCALE

Lighting Control Panel Schedule

LCP Name:	LCP 1
Location:	Electric Room 127
Surface/Flush:	Surface
Power Circuit:	H1:2

Relay #	Circuit	Load	Description	Control	Switching
1	*H1:12	2080	EAST/WEST BLEACHERS-FLUORESCENT	1	a
2	*H1:15	2140	EAST/WEST BLEACHERS-FLUORESCENT	1	b
3	*H1:13	2160	MAIN COURT-FLUORESCENT	1	c
4	*H1:14	2120	MAIN COURT-FLUORESCENT	1	d
5	H1:6	4000	EAST/WEST BLEACHERS-METAL HALIDE	1	e
6	H1:11	4000	EAST/WEST BLEACHERS-METAL HALIDE	1	e
7	H1:7	4000	MAIN COURT-METAL HALIDE	1	g
8	H1:8	4000	MAIN COURT-METAL HALIDE	1	h
9	H1:9	4000	MAIN COURT-METAL HALIDE	1	g
10	H1:10	4000	MAIN COURT-METAL HALIDE	1	h
11	H1:3	3000	PARKING LOT LIGHTING	2	
12	*H1:4	1880	EXTERIOR BUILDING LIGHTING	3	

Scenario Listings

(1) MANUAL ON/ MANUAL OFF
(2) PHOTO ON/PHOTO OFF
(3) PHOTO ON/SCHED OFF

*CIRCUIT EXIT SIGNS AND EMERGENCY LIGHTS AHEAD OF CONTROL PANEL

LIGHTING CONTROL PANEL SHALL HAVE 9 ZONES OF CONTROL. WATTSTOPPER #LI48-277-12-2-277 OR APPROVED EQUAL. SEE SPECIFICATION SECTON 16950.

2 RELAY PANEL SCHEDULE
NO SCALE

HANNEY & ASSOCIATES, ARCHITECTS
1726 South Hillside, Wichita, Kansas, 67211
Phone (316) 683-8985
Fax (316) 684-1441
www.hoarchitects.com

2009
GARDEN PLAIN HIGH SCHOOL - NEW GYM
GARDEN PLAIN, KANSAS
RENWICK UNIFIED SCHOOL DISTRICT 267

DRAWINGS ISSUED		
NO.	DATE	ITEM ISSUED
1	5/1	ADDENDUM NO. 3
1	4/17	FOR BIDS

COMPUTER DRAWING

DATE: APRIL 2009	
DRAWN BY:	CHECKED BY:
JLM	DLD

SHEET
E1.7
OF 16 SHEETS

Professional Engineering Consultants, P.A.
303 S. TOPEKA • WICHITA, KANSAS 67202 • 316.262.2691 • FAX 316.262.3003
www.pec1.com

Saved 05-07-2009 10:14:01 AM by JLL
Plotted 05-07-2009 10:14:10 AM by JLL
E:\2008\08084\002\08084-002-E17-DETAILS