

### **Addendum Number Three**

To The Drawings and Specifications for  
The New Genesis Health Club at 9<sup>th</sup> & Cloud St.  
Salina, Kansas

Issued: September 3, 2009

### **HANNEY & ASSOCIATES ARCHITECTS**

1726 South Hillside, Wichita, Kansas

### **NOTICE TO BIDDERS**

You are hereby instructed to include in your bids the following changes and/or corrections to the Drawings and Specifications for The New Genesis Health Club at 9<sup>th</sup> & Cloud St., Salina, Kansas

The additions and/or corrections shall be considered as a part of the Contract Documents as if incorporated therein. Where the following corrections and/or additions vary from the conditions of the Drawings and Specifications, such following changes or additions shall govern.

#### **I. GENERAL CLARIFICATIONS:**

- 1.1 *The bid date is established by the General Contractor – Rock Enterprises.*
    - 1.1.1 Original drawings are on file with City Blue Print – Wichita. Complete sets can be ordered from City Blue at the bidder's expense.
  - 1.2 Addendum drawings will be forwarded to these plan room as well as posted on our web site [www.haarchitects.com](http://www.haarchitects.com), then click on the "shortcut to plan room".
  - 1.3 All ceilings specified are to be fire rated, even though the fitness area is fire sprinkled. The material does not sag and warp like non-rated tile. The light tents shall be deleted.
  - 1.4 Clarification to Ceiling Type "C2":
    - 1.4.1 The "C2" tile should be defined as two types "C2R" for 2'x2' Radar with standard grid and "C2D" for 2x2 Dune with the Donn Fineline grid. The revised A3.5 is being posted to our website with this addendum for clarifications.
  - 1.5 The room finish schedule incorrectly notes that Rooms A120 & A129 are to receive a lay in grid ceiling system. Both of these rooms are to be G.W.B. as per the reflected ceiling plan.
  - 1.6 There is no hardware schedule issued for this project.
- #### **II. CHANGES TO THE DRAWINGS:**
- 2.1 Sheets A3.5, E2.1 and E2.2 have been revised and are re-issued with this addendum. The revised drawings can be found on our website.

**III. CHANGES TO MECHANICAL:**

- 3.1 HW-3 shown on the upper level is equal to a Lochinvar JRC012EJG12 gallon 3KW 277/1/60 with P&T.

**End of Addendum Three**